APW - VERTICAL PUMPS



PERFORMANCE BASED ON PUMPING CLEAR WATER BELOW 85°F. WITH LISTED MATLS. COLUMN LOSSES NOT INCLUDED.	CHANGE IN EFF. STAGES	POINTS	INGERSOLL-RAND PUMPS VERTICAL PUMP DIVISION HASTINGS, NE	THRUST FACTORS AT BEP		RPM	PUMP
BOWL – CAST IRON – LINED	1	0		IMPELLER	LBS/FT	KG/M	1775	14JKYH
IMPELLER – BRONZE				STANDARD	9.4	14.0	ENCLOSED IMPELLER	CURVE NO.
				BALANCED	--	--	N_s = 1840	EC-1421
				EYE AREA–28.3 SQ. IN.				