APW - VERTICAL PUMPS



PERFORMANCE BASED ON PUMPING CLEAR WATER BELOW 85°F. WITH LISTED MATLS. COLUMN LOSSES NOT INCLUDED.	CHANGE STAGES	IN EFF. POINTS
BOWL – CAST IRON – LINED	1	-2
IMPELLER – BRONZE	2	-1
	3	0

INGERSOLL-RAND
PUMPS
VERTICAL PUMP DIVISION
HASTINGS, NE

THRUST FACTORS AT BEP		
IMPELLER	LBS/FT	KG/M
STANDARD	10.1	15.0
BALANCED	4.0	5.9
EYE AREA–25.0 SQ. IN.		

RPM	PUMP
1775	14KKL
ENCLOSED IMPELLER	CURVE NO.
N_s = 2620	EC–1387