APW - VERTICAL PUMPS



PERFORMANCE BASED ON PUMPING CLEAR WATER BELOW 85°F. WITH LISTED MATLS. COLUMN LOSSES NOT INCLUDED.	CHANGE STAGES	IN EFF. POINTS
BOWL – CAST IRON – LINED	1	3
IMPELLER – BRONZE	2	2
	3	1
	4	0

INGERSOLL-RAND
PUMPS
VERTICAL PUMP DIVISION
HASTINGS, NE

THRUST FACTORS AT BEP		
IMPELLER	LBS/FT	KG/M
STANDARD	3.40	5.07
BALANCED	2.78	4.14
EYE AREA–8.12 SQ. IN.		

RPM	PUMP
1770	8KKH
ENCLOSED IMPELLER	CURVE NO.
N_s = 2370	EC–1369