APW - VERTICAL PUMPS



PERFORMANCE BASED ON PUMPING CLEAR WATER BELOW 85°F. WITH LISTED MATLS. COLUMN LOSSES NOT INCLUDED.	CHANGE STAGES	IN EFF. POINTS
	1	-3
	2	-2
BOWL - CAST IRON - LINED	3	-1
IMPELLER - BRONZE	4	0

INGERSOLL-RAND
PUMPS
VERTICAL PUMP DIVISION
HASTINGS, NE

THRUST FACTORS AT BEP		
IMPELLER	LBS/FT	KG/M
STANDARD	3.60	5.36
BALANCED	2.78	4.14
EYE AREA-8.12 SQ. IN.		

RPM	PUMP
1770	8KKL
ENCLOSED IMPELLER	CURVE NO.
N_s = 2410	EC-1381