

LAYNE & BOWLER, INC.
MEMPHIS, TENN.

DEEP WELL PUMP TEST PERFORMANCE CHART

TEST NO. 7524
DATE 9-10-63

SIZE DISCHARGE COLUMN 14X1 1/4 X 3
SIZE OF SUCTION PIPE 14" C. STE
TYPE OF LUBRICATION Oil

IMPELLER 8H17
FILING None
DIAMETER Full - 11 9/16

PUMP NO. 47402
ORDER NO. 630-2791

ENAMEL INTS.

CUSTOMER Chief Joseph Dam Project
SUBSIDIARY LAYNE & BOWLER INC.

SIZE OF PUMP 16"
TYPE OF PUMP FIGURE HH
NUMBER OF STAGES 2
R. P. M. 1770

