


CURVE NO. 8L3AF-2

Test No. 1498

CHANGE EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
LOWER	3	1
LOWER	2	2

NOTE: ANY CHANGE IN EFFICIENCY
CHANGES EITHER THE HEAD OR
HORSE POWER IN PROPORTION



HYDRAULIC PERFORMANCE is contingent on the well furnishing the pump with the specified amount of clear, fresh, non-aerated water at a temperature of not to exceed 85 degrees Fahrenheit.

POMONA PUMPS
 Fairbanks, Morse & Co.

Chicago 5,
 Illinois

Pomona
 California

LABORATORY PERFORMANCE **PE**
 PER STAGE **8 LC** DEEP WELL TURBINE
 PUMP OPERATED AT **1760** R. P. M.
 FIELD LOSS MUST BE DEDUCTED