


CURVE NO. 24M3AA-1

Test No. 1555

CHANGE IN EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
Lower	5	1
Lower	1	2

NOTE: ANY CHANGE IN EFFICIENCY
CHANGES EITHER THE HEAD OR
HORSE POWER IN PROPORTION.



HYDRAULIC PERFORMANCE is contingent on the well furnishing the pump with the specified amount of clear, fresh, non-aerated water at a temperature of not to exceed 85 degrees Fahrenheit.

POMONA PUMPS
Fairbanks, Morse & Co.


Chicago 5,
Illinois

Pomona
California

LABORATORY PERFORMANCE
PER STAGE **24MC** DEEP WELL TURBINE
PUMP OPERATED AT **720** R. P. M.
FIELD LOSS MUST BE DEDUCTED

CURVE NO. 24M3AA-2
TEST NO. 1513, 1543

CHANGE EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
Lower	5	1
Lower	1	2
NOTE: ANY CHANGE IN EFFICIENCY CHANGES EITHER THE HEAD OR HORSE POWER IN PROPORTION.		



HYDRAULIC PERFORMANCE is contingent on the well furnishing the pump with the specified amount of clear, fresh, non-aerated water at a temperature of not to exceed 85 degrees Fahrenheit.

POMONA PUMPS
Fairbanks, Morse & Co.

Chicago 5,
Illinois

Pomona
California

LABORATORY PERFORMANCE
PER STAGE 24 MC DEEP WELL TURBINE
PUMP OPERATED AT 720 R. P. M.
FIELD LOSS MUST BE DEDUCTED