




A Sterling Company

VERTICAL TURBINE PUMPS

Stages _____ of raw water

Total Head in Feet for _____ Stages

CHANGE EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
Lower	.2	4
"	.4	1
NOTE: ANY CHANGE IN EFFICIENCY AFFECTS EITHER THE HEAD OR HORSE POWER CORRESPONDINGLY		



HYDRAULIC PERFORMANCE WARRANTY Guaranteed at designated point only, and contingent on: Proper flow to pump suction Proper submergence Fluid free of gas, air & abrasives Proper lateral setting of impeller	CURVE NO.	IMPELLER NO.	IMP. DIA. & FILING	TEST NO.	Customer _____
	1	2626082	10.25 x 10.875 STREAMLINE TO 0.06	42513	Item _____
	2	2626082	10.25 x 10.875 DEBURR ONLY	42731	Peerless Ref. No: _____
	3	2626082	9.937 x 10.625 DEBURR ONLY (STD)		Laboratory Performance
	4	2626082	9.625 x 10.375 DEBURR ONLY (STD)	51238	SIZE 14 MC RPM 1760 CURVE 4805574
	5	2626082	9.125 x 9.875 DEBURR ONLY (STD)	42650	

PUMP DESCRIPTION: Driver _____; Head _____; Column _____
 GUARANTEED BOWL ☐ PERFORMANCE: Capacity _____ gpm; Head _____ ft; Eff _____ %; BHP _____
 FIELD ☐