

Supersedes:

Date 1-20-59

Page 8.75

BERKELEY PUMP COMPANY

Deepwell Turbine Rating Curves

Section 5055

4-15-64 No. 8,75

Enclosed Impeller

1760 R.P.M.

Supersedes C-944

Date 3-6-52

Drawn: C P B L-679

Impeller: C P B L-580


O. D. 11 1/2

Full Dia. 7 1/2 x 9

Single Stage Performance, 4 Stage Pump

CORRECT EFFICIENCY AS FOLLOWS:

Stages	Points
4	0
3	-1
2	-2
1	-5



C-5440 BASED ON T. 2282

Date 5-31-63

MODEL

1203HH