

Supersedes:

Date

Page

BERKELEY PUMP COMPANY

Deepwell Turbine Rating Curves

Section 5055

4-15-64 No. 3.82

Enclosed Impeller

3450 R.P.M.

Supersedes NEW
Date


Bowl: C P M-4071
Impeller: C P M-4043

O. D. $5\frac{3}{8}$
Full Dia. $3\frac{7}{8} \times 4\frac{17}{32}$

Single Stage Performance, 4 Stage Pump

CORRECT EFFICIENCY AS FOLLOWS:

Stages	Points
4	0
3	-1
2	-2
1	-5



C-5449 BASED ON T. 2287

Date 6-11-63

MODEL
↓

602AM