






IMPELLER TYPE = ENCLOSED	STD. SHAFT DIA. = 1.000"	NO. STAGES	EFF. CHANGE	MATERIAL	B.E.P. EFF. CHANGE
IMPELLER NO. = SS6M	MAX. SHAFT DIA. = 1.000"	1	-4	IMP. - C.I.	-3
IMPELLER WT. - LBS. = 2.95	STD. LATERAL = .625"	2	-3	IMP. - NI-RI	-2
ONE STAGE WT. - LBS. = 56.0	DISCHARGE SIZES = 3", 4"	3	-2	IMP. - S.S.	-4
ADD'L STAGE WT. - LBS. = 19.0	SUCTION SIZES = 4"	4	-1	BOWL - BRZ.	-3
MAX. SPHERE SIZE = .312"	ONE STAGE WR ² = .037	5	0	BOWL - NI-RI	-1
MIN. SUBMERGENCE* = 11"				BOWL - S.S.	-4

Δ CONSULT FACTORY



SUBMERSIBLE TURBINE



LINESHAFT TURBINE